



SOUTH SHORE FIRE DEPARTMENT

3900 Old Green Bay Road - Mt Pleasant - WI 53403 – 262-995-1200 – 262-995-1208 Fax

BUILDING ADDRESS

Per the International Fire Code (2009 ed.) Sec. 505 Premises identification shall be a minimum of 101.6 mm (4 in.) high with a minimum stroke width of 12.7 mm (0.5 in.). Exterior numbering shall be approved Arabic numbers or alphabetical letters. They shall be visible from the street or closest traffic way / driveway, contrasting with their background and Retro-reflective for low light or smoky conditions. It would be further required that the numbering be of correct size in correlation with how far the building is from the street or FD access.

- Up to 36 feet away as specified above
- Structures 36 to 50 feet away: numbers a minimum of (6) inches high with (0.5) in. stroke width
- Structures more than 50 feet away: numbers a minimum of (9) in. high with a (1) in. stroke width

We will work with building owners to meet corporate and esthetic needs, as long as design meets the requirements of the jurisdiction's planning commission.

DOOR NUMBERING

We require contrasting numbers on the man doors. Numbering is to begin at front face (street side) of the building, reading from left to right. Glass/aluminum clad doors may be skipped at owner's discretion. however, do not skip number sequence.

Overhead and dock bays may not be numbered in a manner as to confuse man door numbering. It is recommended occupants inside the building be able to identify the exterior number without exiting the building.

FIRE PROTECTION SYSTEM & ROOF ACCESS

"Sprinkler", "Fire Pump", "FACP" (fire alarm control panel), and "Roof" access need to be identified with red decals or paint, as such for exterior access. Placards adjacent to interior doors are acceptable but will also require red lettering. Backgrounds only need to contrast the red lettering.

Ed Lockhart

Division Chief

South Shore Fire Department

3900 Old Green Bay Road

Mt. Pleasant, WI 53403

262-995-1211 Office Direct

262-995-1200 Fire Dept.

262-995-1208 Fax